495 Quail Run Rd Bozeman, MT 59718 Office: (406) 585-4166				Pre-Bury Service Connection Checklist Contractor to notify FCWSD 24 hours prior to beginning installation of any service to schedule inspection times Failure to give 24 hour advanced notice may delay inspection up to 24 hours. Operators: Christine 406-595-3113 Louie 406-581-2403 Colbie 406-581-2246		
			495 Quail Run Rd Bozeman, MT 59718			
				Residential Service	Commercial Service	
			Permit #			
WATER SERVICE	VICE	FCWSD	Subdivision:	Block:	Lot:	
	SER	l by F(Address:		Owner:	
	SEWER SERVICE	Verified by	Builder/Applicant:		Phone:	
			FCWSD notified 24 hours in advance of inspection			
			Minimum 8' horizontal separation between Water and Sewer services			
			Minimum 6" vertical separation at Water-Sewer crossings			
			One Water service per individual service unit or meter closet, no shared meters except for ADU			
			6.5' minimum cover placed over Water service line using appropriate bedding materials			
			Poly pipe with Compression fittings only. No Copper on any buried service line			
			Nonpotable water from irrigation does not enter the building. No cross connections			
			No couplers/ferncos on line without prior approval. Pressure test lines where applicable			
			Sewer line tv inspection. Clear of debris/ no broken pipe/ no obvious bellies			
			Double sweep tee cleanout placed outside building within 3 feet from building			
			Double sweep tee every 100 feet on straight runs and at bends per UPC code			
			Minimum pipe slope of 1/4" per foot (2.00%) on Sewer service laterals for 4" pipe			
			Pipe bedded 4 inches under Sewer service pipe and 6 inches over pipe with approved bedding			
			Appropriate pre-treatment device installed if required. No floor drains connected to sewer service			
			FOR ADU: Water line from curbstop to main house and stub from house to ADU(will share a meter)			
			Sewer line to be wyed into service from main house. Same rules for cleanouts/grade/bedding			

Inspected by: