

495 Quail Run Road, Bozeman, MT 59718
(406) 585-4166, admin@fcwdsd.org

The contractor/excavator will use this checklist to verify new water and sewer services have been installed following District guidelines. After completing this form, notify FCWSD at least ONE (1) business day in advance when the service is ready for inspection and connection to the public water system: (406) 585-4166



WATER SERVICE
SEWER SERVICE
 Verified by FCWSD

Owner / Applicant Name	Phone (Work / Mobile)
Property Address	FCWSD Permit #
Subdivision	Lot Block
Contractor / Excavator Name	Phone (Work / Mobile)

			Minimum 8' horizontal separation between WATER and SEWER services
			Minimum 6" vertical separation at WATER-SEWER crossings
			One WATER service per individual service unit (as per Ordinance 2015-05)
			Minimum of 6.5' cover placed over WATER service line using appropriate bedding materials
			Minimum 8' horizontal separation between potable water and external irrigation services
			External irrigation system does not connect in any way to potable WATER service or enter building
			One SEWER service per individual service unit
			SEWER cleanouts placed within 3' of building, at any 45-degree or greater bend, at pipe size transition points, --- and placed every 100' in compliance with Uniform Plumbing Code
			Minimum pipe slope of 1/4" per foot (2.00%) on SEWER service laterals
			Pipe bedded 4 inches under SEWER service lateral and 6 inches over service lateral --- using 1 inch minus washed bedding material
			Check measurements and make an as-built drawing sketch on the back of this sheet or attach other.

Inspected by: _____

Date: _____

NOTES:

As-Built Drawing of Water / Sewer Connections